

FIDDLETOWN COMMUNITY SERVICES DISTRICT

PO BOX 35, FIDDLETOWN, CALIFORNIA, 95629

209.245.3991 fiddcsd@gmail.com

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este aviso contiene información muy importante sobre su agua potable, por favor lea el aviso en español si va aquí incluido. Si el aviso en español no va incluido aquí, contacte al sistema de agua para pedir una copia.

Fiddletown Community Service District Has Levels of Iron Above the Secondary Maximum Contaminant Level

Our water system recently violated the Secondary Maximum Contaminant Level (MCL) for iron. Secondary standards primarily affect the color and taste of the water delivered to customers. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample results received on 5/5/2026 showed:

1) Iron levels of 0.84 mg/L. This is above the secondary MCL of 0.3 milligrams per liter (mg/L).

What should I do?

You do not need to use an alternative water supply (e.g., bottled water).

This is not an emergency. If it had been, you would have been notified immediately. However, some people may notice water discoloration, and possibly taste and/or odor issues with their drinking water. This is not considered a health concern.

If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

The district is working with State SAFER Program to engineer a permanent solution. This program is designed for small districts like ours with minimal resources and low- income residents. We anticipate resolving the problem within the next year.

For more information, please contact Fiddletown Community Service District at fiddcsd@gmail.com. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Fiddletown Community Service District.

State Water System Number: CA0300019. Date distributed: 7/17/2026.